

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382,

E-mail : erda@erda.org

Web : <http://www.erda.org>



TEST REPORT		SHEET 1 OF 2
NAME & ADDRESS OF CUSTOMER HPS Exim Private Limited. 988/16/2, G.I.D.C. Industrial Estate Makarpura, Vadodara-390 010	REPORT No. DATE	RP-1617-003629 26-04-2016
	CUSTOMER REF No. DATE	Letter 19-04-2016
	DATE OF SAMPLE RECEIPT	DATE OF TESTING
	19-04-2016	21-04-2016
SAMPLE DESCRIPTION FRP Spacer tube-1 No.	SAMPLE IDENTIFICATION ERDA Sample Code No.: ERDA-00138200	
Sr. No.	TEST DETAILS	TEST SPECIFICATION
1.	Electric strength	IEC 60243-1:2013
<div><div> PREPARED BY</div><div> CHECKED BY</div><div> (S.M. Falnikar) APPROVED BY</div></div>		
Note	1 This report relates only to the particular sample received for testing in good condition at ERDA. 2 This report cannot be reproduced in part under any circumstances. 3 Publication of this report requires prior permission in writing from Director, ERDA. 4 Only the tests asked for by the customer have been carried out. 5 In case any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arised.	
Caution	ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.	



1851014

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.


EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382,

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT No. RP-1617-003629		DATE 26-04-2016		SHEET 2 OF 2	
Sr. No.	Particular of Tests & Cl. No.	Requirements as per specification	Observed values	Remarks	
1.	Electric strength, ac, kV (Proof voltage test) in oil at 90 °C, edgewise (across 25mm) Cl. No. 10.6	Samples shall withstand the test voltage of 50kV for 5 minutes.	Specimen-1: Withstood Specimen-2: Withstood Specimen-3: Punctured at 50kV, 5 Seconds	Conforms Conforms Does not Conform	
Note: Requirement values are specified by the customer.					
PREPARED BY 		CHECKED BY 